



813 Downtowner Boulevard
Suite D
Mobile, Alabama 36609
P: 251.316.0015 • F: 850.332.6629
www.dellconsultingllc.com

Memorandum

Date: *March 18, 2020*

To: All Parties involved with bidding or
Construction Holy Spirit Hall

From: Andy Maurin, P.E.

Regarding: ARC FAULT
PROTECTION/BREAKERS

This memo is to supplement the documentation for the Sacred Heart Church Holy Spirit Hall plans and specifications. The Panelboards are to be provided with ARC Fault Circuit-interrupter Breakers to meet the requirements of the National Electrical Code Article 210.12.